



Economic aspects of a full-scale packed bed CLC reactor, comparison with other zero emission technologies



DEMOCLOCK Business Brunch

Katowice, 13rd December 2016



Luca Mancuso
Process Director, Amec Foster Wheeler

Agenda

1. Introduction

- a. Amec Foster Wheeler at a glance
- b. What is CCS technology?
- c. Technical and Policy challenges

2. Results of the Techno-economic assessments

- a. Plant summary
- b. Methodological approach
- c. Total Plant Cost
- d. O&M
- e. LCOE, CAC
- f. Sensitivity cases

3. Summary Considerations

Agenda

1. Introduction

- a. Amec Foster Wheeler at a glance
- b. What is CCS technology?
- c. Technical and Policy challenges

2. Results of the Techno-economic assessments

- a. Plant summary
- b. Methodological approach
- c. Total Plant Cost
- d. O&M
- e. LCOE, CAC
- f. Sensitivity cases

3. Summary Considerations

Who we are

Amec Foster Wheeler at a glance



Market mix by revenue

- Mining, Environment & Infrastructure,
- Clean Energy, Oil & Gas



7%



12%



27%




54%

- Upstream 28%
- Midstream 4%
- Downstream 22%

Business units

Americas, Northern Europe & CIS (NECIS),
Asia, Middle East, Africa & Southern Europe (AMEASE),
Global Power Group (GPG)



36,000 people worldwide

160+ year history



Operating in over 55 countries



Revenue £5.5bn



Trading symbol

Economic assessment of full-scale CLC plant

Aim

Prepare the commercialization of the new CLC technology, attracting NEW customers for further developments

Objectives

- ▶ Evaluation of the cost of electricity (COE) and of CO₂ avoidance cost (CAC) in IG-CLC-CC integrated plants using packed bed reactors
- ▶ Comparison with benchmark technologies with near Zero emissions (Carbon Capture and Storage, CCS)
- ▶ Sensitivity economic analyses



What is CCS Technology?

“Full Chain CCS” is broken down into three steps:



▶ CO₂ Capture (benchmark technologies)

- ▶ Post Combustion
- ▶ Pre Combustion
- ▶ Oxy Combustion

▶ CO₂ Transportation

- ▶ Pipeline
- ▶ Ship
- ▶ Truck

▶ CO₂ Storage


- ▶ Depleted Reservoirs
- ▶ Saline Aquifer
- ▶ Enhanced Oil Recovery



from White Rose Project

Carbon Capture utilisation and storage

Benchmark technologies



Source: EPRI (2011a, p1-1)

Technical Challenges

- ▶ Post-Combustion Capture
 - ▶ size (volume) of equipment
 - ▶ prevention of emission of amine derivatives from absorber
- ▶ Pre-combustion Capture
 - ▶ plant complexity
- ▶ Oxy-combustion Capture
 - ▶ less demonstrated at scale
- ▶ All – Energy penalty (and hence higher running costs) compared to **unabated** fossil fuel power generation
- ▶ Transportation – maintaining desired phase
- ▶ Storage – ensuring full and safe containment

None of these are show-stoppers



Policy Challenges

- ▶ Public acceptance
- ▶ Who pays for the additional cost versus unabated power generation?
- ▶ How to incentivise investment?
- ▶ Who pays for the CO₂ transportation network & storage sites?
- ▶ Who is liable to keep the storage sites running safely in 20, 50, 200 years time?



Agenda

1. Introduction

- a. Amec Foster Wheeler at a glance
- b. What is CCS technology?
- c. Technical and Policy challenges

2. Results of the Techno-economic assessments

- a. Plant summary
- b. Methodological approach
- c. Total Plant Cost
- d. O&M
- e. LCOE, CAC
- f. Sensitivity cases

3. Summary Considerations




Assessed Plant configuration summary

Case	Feedstock	Technology	Main Product	CCS	Combustion Technology
1	Coal	IGCC	Power	No	GT
2	Coal	IGCC	Power	Yes	GT
3	Coal	IGCC	Power	Yes	CLC (PBR)
4 (*)	Coal	SC-PC	Power	No	Air-boiler
5	Coal	SC-PC	Power	Yes	Air-boiler
6	Coal	Oxy-SC-PC	Power	Yes	Oxy-boiler

(*) Reference technology for CO₂ avoidance cost calculation



Plant overview





Plant performance

Case 3: IGCC plant with CO₂ capture (CCS) and Chemical Looping Combustion (CLC)

Coal input [t/h]	122.9	
Coal thermal input [MW _{LHV}]	853.9	
Gas Turbine Electric Power Output [MW]	175.2	
Steam Turbine Electric Power Output [MW]	240.6	
Auxiliary Power Demand [MW]	67.0	
Net Electric Plant Output [MW]	348.8	35.3% IGCC
Electric Efficiency [%_{LHV}]	40.8	35.2% USCPC
CO ₂ mass flow rate release to ambient [t/h]	11.7	35.7% OxyPC
Specific Emission of CO ₂ [g/kWh]	33.5	
Carbon Capture Ratio [%]	96.1	~ 90% others



Methodological approach

Sequential steps


1. Acquisition/finalization of plant performance and H&MBs
2. Preparation of sized equipment list
3. Estimate Total Plant Cost (TPC) and Total Capital Requirement (TCR)
4. Estimate the Operating and Maintenance costs (O&M)
5. Estimate the plant revenues
6. Calculate the Levelized Cost of Electricity (LCOE)
7. Calculate of the CO₂ avoidance cost (CAC)
8. Comparison between plants adopting benchmark technologies (SC-PC and IGCC) and CLC plant

$$\text{CO}_2 \text{ Avoidance Cost (CAC)} = \frac{\text{LCOE}_{\text{CCS}} - \text{LCOE}_{\text{Reference}}}{\text{CO}_2 \text{ Emissions}_{\text{Reference}} - \text{CO}_2 \text{ Emissions}_{\text{CCS}}}$$

9. Sensitivity analyses (main key factors) in order to estimate the attractiveness of CLC plants

Main input data for CLC Packed Bed Reactor

- ▶ Performance at lab scale
- ▶ Packed Bed Reactors (PBR) in vertical CS pressure vessels coated with refractory surface
- ▶ 14 reactors (I.D. 5.5m, I.L. 11m)
 - ▶ 3 oxidation phase
 - ▶ 3 reduction phase
 - ▶ 7 heat removal phase
 - ▶ 1 purge phase
- ▶ Bed material lifetime: 5 years
- ▶ Industrial specific bed material cost: 2,500 €/t




Total Plant Cost (TPC)

Bases and methodology

Defined in general accordance with the White Paper *“Toward a common method of cost estimation for CO2 capture and storage at fossil fuel power plants”* (March 2013), produced collaboratively by authors from EPRI, IEAGHG, Carnegie Mellon University, MIT, IEA, GCCSI and Vattenfall

Total Plant Cost



EPC services included in above items / Project Contingency: 10% of the above items.

Total Plant Cost (TPC) Case 3




Project Democlock
Date: May 2015 REV. 0

CASE 3 - ESTIMATE SUMMARY (IGCC w CCS & CLC)




POS	DESCRIPTION	Unit 900 €	Unit 950 €	Unit 1000 €	Unit 1500 €	Unit 2000 €	Unit 2100 €	Unit 2200 €	Unit 2300 €	Unit 3000 €	Unit 4000 €	TOTAL €	REMARKS
1	DIRECT MATERIALS	77,011,000	21,472,000	144,107,000	91,960,000	13,548,000	17,907,000	16,975,000	16,495,000	151,217,000	104,998,000	655,690,000	1) ESTIMATE ACCURACY +/- 35% 2) TODAY COSTS @ 1Q2015 3) EXCLUSIONS: TAXES AND LOCAL AUTHORITIES CAPITAL AND OPERATION SPARE PARTS START-UP COSTS FINANCIAL/LEGAL/INSURANCE COSTS OWNER'S COST 4) 10% PROJECT CONTINGENCY 5) EPC SERVICES COSTS INCLUDED UNIT 900 ASU 950 Storage and Handling of solid materials 1000 Gasification Island 1500 Chemical Looping Combustion 2000 Syngas treatment & conditioning line 2100 Acid Gas Removal 2200 SRU & TGT 2300 CO ₂ Compression & Drying 3000 Combined Cycle 4000 BOP Utilities&Offsites 349 MWe, Net Power Output 3099 €/kWe, Specific Investment Cost
2	CONSTRUCTION	32,871,000	7,472,000	60,224,000	20,770,000	8,635,000	13,359,000	10,609,000	11,547,000	67,709,000	29,712,000	262,908,000	
3	OTHER COSTS	5,494,000	1,589,000	10,109,000	14,339,000	1,526,000	2,274,000	6,302,000	2,026,000	13,361,000	6,996,000	64,016,000	
4	TOTAL INSTALLATION COST	115,376,000	30,533,000	214,440,000	127,069,000	23,709,000	33,540,000	33,886,000	30,068,000	232,287,000	141,706,000	982,614,000	
5	PROJECT CONTINGENCY	11,538,000	3,053,000	21,444,000	12,707,000	2,371,000	3,354,000	3,389,000	3,007,000	23,229,000	14,171,000	98,263,000	
TOTAL PLANT COST		126,914,000	33,586,000	235,884,000	139,776,000	26,080,000	36,894,000	37,275,000	33,075,000	255,516,000	155,877,000	1,080,877,000	





Specific Total Plant Cost



Total Capital Requirement (TCR)

Bases and methodology


Total Capital Requirement (TCR) is the sum of the TPC and the following items:

- ▶ *Interest during construction*, assumed same as discount rate (8%)
- ▶ *Spare parts cost*, assumed as 0.5% of the TPC
- ▶ *Working capital*, including 30 days inventories of fuel and chemicals
- ▶ *Start-up costs*, consisting of:
 - ▶ 2% of TPC to cover modifications to equipment that are needed to bring the unit up to full capacity
 - ▶ 25% of fuel cost for one month to cover inefficient operation that occurs during the start-up period
 - ▶ 3 months O&M costs to include training
 - ▶ 1 month of catalyst, chemicals and maintenance materials costs
- ▶ *Owner's costs*, assumed as 7% of TPC

TCR is typically 30-35% higher than TPC



Operating & Maintenance (O&M) costs





Labour cost

Number of personnel required to operate the plant
 IGCC: 133 people SC-PC: 105 people

Coal IGCC Plants					
	ASU	Gasification	Power Island & Utilities	TOTAL	Notes
OPERATION					
Area Responsible	1	1	1	3	daily position
Assistant Area Responsible	1	1	1	3	daily position
Shift Superintendent	5			5	1 position per shift
Electrical Assistant	5			5	1 position per shift
Shift Supervisor	5	5	5	15	3 positions per shift
Control Room Operator	5	10	10	25	5 positions per shift
Field Operator	5	30	20	55	10 positions per shift
Subtotal				111	
MAINTENANCE					
Mechanical group	4			4	daily position
Instrument group	7			7	daily position
Electrical group	5			5	daily position
Subtotal				16	
LABORATORY					
Superintendent+Analysts	6			6	daily position
Subtotal				6	
TOTAL				133	



Maintenance cost

- ▶ Estimated as a percentage of the TPC


Power plants	
Plant Sections	Maintenance cost as percentage of the total installed cost
Gasification Island	3.0 %
Feedstock handling and storage, CO ₂ compression, Boiler Island, DeNO _x , DeSO _x , CPU	2.5 %
ASU, AGR, SRU&TGT, Syngas Treatment, CLC unit, CO ₂ amine abs.	2.0 %
Balance of Plant	1.5 %
Combined Cycle ⁽¹⁾	5.0 %
Steam Cycle ⁽²⁾	2.0 %

Note: 1) IGCC-based plants;
2) SC-PC-based plants.

- ▶ Statically split as 60% maintenance materials and 40% maintenance labour



Example of O&M costs

amec foster wheeler 	IGCC-BASED CASES O&M COSTS (2015)		
	Case 1 €/year	Case 2 €/year	Case 3 €/year
Fixed Costs			
Direct labour	6,650,000	6,650,000	6,650,000
Adm./gen overheads	1,995,000	1,995,000	1,995,000
Insurance & Local taxes	9,066,200	10,047,400	10,808,800
Maintenance	27,742,700	29,941,100	31,237,300
Subtotal	45,453,900	48,633,500	50,691,100
Variable Costs (Availability = 87%)			
Feedstock	59,556,000	65,874,000	62,590,000
Water Makeup	911,000	1,113,900	1,089,600
Catalyst	74,000	2,096,000	1,088,000
Chemicals (including Solvent)	1,542,000	1,723,000	1,688,000
CLC bed material	0	0	5,752,000
Subtotal	62,083,000	70,806,900	72,207,600
TOTAL O&M COSTS	107,536,900	119,440,400	122,898,700
Specific O&M COSTS (€/kWh)	0.038	0.049	0.046

The operating lifetime of the packed bed reactor material leads to higher O&M costs (replacement cost)




Simplified Financial Analysis

Main macroeconomic assumptions

Item	Cost
Coal	2.6 €/GJ _{LHV} 65.05 €/t
Limestone	40 €/t
Raw water	0.2 €/m ³
Sulphur selling price	80 €/t
Ash, slag and gypsum net disposal cost	0 €/t
CO ₂ transport and storage	10 €/t _{stored CO₂}
CO ₂ emission cost	0 €/t _{emitted CO₂}
CLC bed material	2,500 €/t

Levelized Cost of Electricity (LCOE)


- ▶ LCOE of the CLC plant is slightly lower than the one of the benchmark IGCC
- ▶ SC-PC based power plants show lower LCOE





CO₂ Avoidance Cost (CAC)


- Based on CAC, CLC plant is more attractive than benchmark IGCC and SC-PC plants with CCS, due to its higher intrinsic CO₂ capture rate



Sensitivity analyses

CLC bed lifetime


- ▶ Affects maintenance and operating costs (replacement) of the CLC unit
- ▶ CLC plant is more attractive than IGCC and SC-PC plants with CCS when the bed lifetime is respectively greater than 9 months and 3.25 years



Sensitivity analyses

CLC bed material cost


- ▶ Affects both investment and maintenance/replacement costs of the CLC unit
- ▶ CLC plant is more attractive than IGCC and SC-PC plants with CCS when the bed material cost is respectively lower than 9,000 €/t and 3,200 €/t



Sensitivity analyses

CLC reactor performance

- Affects required bed surface/volume or reactor vessel number. In turn, both investment and maintenance/replacement costs of the CLC unit are affected



Agenda

1. Introduction

- a. Amec Foster Wheeler at a glance
- b. What is CCS technology?
- c. Technical and Policy challenges

2. Results of the Techno-economic assessments

- a. Plant summary
- b. Methodological approach
- c. Total Plant Cost
- d. O&M
- e. LCOE, CAC
- f. Sensitivity cases

3. Summary Considerations

Summary Considerations

- ▶ Carbon dioxide Avoidance Cost of the CLC plant is lower than the cost of the gasification and similar to those of the boiler plants with carbon capture
 - ▶ **Higher net electric efficiency of the CLC technology (40.8%)**
 - ▶ **Higher carbon capture rate (96.1%)**
- ▶ CLC unit (bed material, reactor pressure vessels, heat recovery section) requires additional capital requirement
- ▶ Some technological barriers need to be overcome before commercialization of the packed bed CLC process in a full-scale power plant
- ▶ CLC technology is an **ATTRACTIVE OPTION** for carbon dioxide capture in power plants, especially if further improvements of the bed material performance / lifetime / cost will be achieved in the future

Look forward for **NEW COMPANIES** to demonstrate the scalability of the process and its **FULL PROFITABILITY** at large scale



amec
foster
wheeler

amecfw.com

